

proceq

SCHMIDT OS-120
OPERATING INSTRUCTIONS



Contents

1. Safety and Liability	2
1.1 Safety and Usage Precautions	2
1.2 Liability	2
1.3 Safety Instructions	2
1.4 Designated Use	2
2. Instrument Selection	3
2.1 Schmidt OS-120 Models	3
3. Schmidt OS-120 Layout	3
4. Measuring and Evaluation with the Schmidt OS-120PT	4
4.1 Functional Check	4
4.2 Preparations	5
4.3 Measuring	6
4.4 Conversion Curves for Schmidt OS-120PT	6
5. Measuring and Evaluation with the Schmidt OS-120PM	9
5.1 Functional Check	9
5.2 Preparations	9
5.3 Measuring	9
5.4 Rating Table for Schmidt OS-120PM	10
6. Technical data	10
7. Standards and Guidelines	11
7.1 Standards	11
7.2 Guidelines	11
8. Part Numbers and Accessories	11
8.1 Units	11
8.2 Accessories	12
9. Maintenance and Support	12
9.1 Maintenance	12
9.2 Support Concept	12
9.3 Standard Warranty and Extended Warranty	12

1. Safety and Liability

1.1 Safety and Usage Precautions

This manual contains important information on the safety, use and maintenance of the OS-120PT/PM. Read through the manual carefully before the first use of the instrument. Keep the manual in a safe place for future reference.

1.2 Liability

Our “General Terms and Conditions of Sale and Delivery” apply in all cases. Warranty and liability claims arising from personal injury and damage to property cannot be upheld if they are due to one or more of the following causes:

- Failure to use the instrument in accordance with its designated use as described in this manual.
- Incorrect performance check for operation and maintenance of the instrument and its components.
- Failure to adhere to the sections of the manual dealing with the performance check, operation and maintenance of the instrument and its components.
- Unauthorized structural modifications to the instrument and its components.
- Serious damage resulting from the effects of foreign bodies, accidents, vandalism and force majeure.

All information contained in this documentation is presented in good faith and believed to be correct. Proceq SA makes no warranties and excludes all liability as to the completeness and/or accuracy of the information.

1.3 Safety Instructions

The instrument is not allowed to be operated by children or anyone under the influence of alcohol, drugs or pharmaceutical preparations. Anyone who is not familiar with this manual must be supervised when using the instrument.

1.4 Designated Use

- The instrument is only for its designated purpose as described in these operating instructions.
- Replace faulty components only with original replacement parts from Proceq.
- Accessories should only be installed or connected to the instrument if they are expressly authorized by Proceq. If other accessories are installed or connected to the instrument then Proceq will accept no liability and the product guarantee is forfeit.

2. Instrument Selection

2.1 Schmidt OS-120 Models

There are two models available.

- OS-120PT for testing concrete in the very low compressive strength range. Typically from 1 N/mm² to 5.0 N/mm² (145 psi – 725 psi). This makes the instrument very suitable for testing fresh concrete to determine the time for formwork removal.
- OS-120PM for testing the mortar joints in brick constructions.

3. Schmidt OS-120 Layout



- 1 Housing with handle
- 2 Reset lever
- 3 Hammer complete (PM/PT)
- 4 Trigger button
- 5 Scale (Rebound value)
- 6 Control knob
- 7 Hammer head (PM/PT)
- A Contact surface
- B Loading position



Hammer head Schmidt OS-120PT (7)



Hammer head Schmidt OS-120PM (7)

4. Measuring and Evaluation with the Schmidt OS-120PT

The OS-120PT is primarily used to measure the early compressive strength of concrete non-destructively. Measurements can also be made on lightweight concrete, plasterboard and similar products.



NOTE! At all times ensure that all your body parts are kept away from the space between the hammer head (7) and the contact surface A.

4.1 Functional Check

A test anvil is necessary for the functional check of the rebound hammer (see chapter 8.2).



(typically)
Accuracy of rebound values: For OS-120 PT 176 ± 3
For OS-120 PM 186 ± 3

Checking the Schmidt OS-120PT on the test anvil

The functional check should ideally be performed before and after each usage of the hammer. As a minimum it should be carried out after 1'000 impacts or once every three months.

- Insure that the control knob (6) is set at the position H. If not proceed with steps 1 to 6 as described in Chapter 4.2.
- Place the test anvil on a hard, smooth surface (e.g. stone floor).
- Clean the contact surfaces of the anvil and the hammer head.
- Carry out a few impacts on the anvil.
- Perform 10 test impacts on the test anvil.



NOTE! The mean of the rebound values must lie within the tolerance given on the anvil. If this is not the case, e.g following an impact, the hammer mass is not held at the maximum rebound position, then the brake strip must be cleaned.

- Clean the brake strip on the under side of the semi-circular housing (1) using a clean cloth soaked in Acetone. When cleaning with Acetone the paint close to the brake surface may be affected. Alternatively, methylated spirit that does not damage the paint can be used.




- Repeat the functional check.

If the mean value is still out of tolerance, the instrument must be taken to an authorized service centre for re-calibration.

4.2 Preparations

If necessary, use the grinding stone to remove cement residues from the test surface.



- The control knob (6) must be at the desired position V (for testing on vertical surfaces) or H (for testing on horizontal surfaces).

If this is not the case proceed as follows:

1. Place the OS-120 on a flat surface with the scale up and the hammer (3) at loading position B as shown in the first picture of chapter 3.
2. Release the hammer (3) by pushing the reset lever (2) in a downwards direction, keep holding.
3. Press, hold down and release the trigger button (4) to move the entire hammer (3) to the position 75 on the scale (5).
4. Push reset lever (2) down to hold the hammer (3) in place.
5. Turn the control knob (6) to position V for testing on a vertical surface, respectively to H for testing on a horizontal surface.
6. Push hammer (3) back to position B. It will click into loading position.



NOTE! The hammer (3) MUST be set to position 75 to enable you to select V or H with the control knob (6).

4.3 Measuring

1. Place the OS-120 on a flat surface. Check that hammer (3) is at loading position B.
2. Push the reset lever (2) in a downward direction at loading position B.
3. Go to the test location.
4. Grip the OS-120PT by the handle on the housing (1). Exert a light pressure against the test surface towards the side where the contact surfaces (A) of the housing (1) are located. This ensures that the contact surfaces (A) lie flush against the surface (see the pictures below).



5. Trigger the impact by pressing the trigger button (4).
6. Read the rebound value from the scale (5).
7. Push the hammer (3) back to position B to perform the next impact.

Repeat the procedure as many times as the standard you are working to requires. For example, EN 12504-2 requires a minimum of 9 rebound values for calculating the median.

The rebound value determined in this way can be converted to a compressive strength estimate using the conversion curves (See chapter 4.4.) However, we recommend the creation of a user defined curve specifically for the concrete under test. An EXCEL Macro is available with the product documentation and also on the Proceq website to assist with this.

When the measurement is completed:

- Check the Schmidt OS-120PT on the anvil. (see chapter 4.1).
- Put the Schmidt OS-120PT into the neutral position. i.e. set the Schmidt OS-120PT on a horizontal surface (e.g. leave it on the anvil after the control check), set the control knob (6) to position V, depress the reset lever (2) to bring the hammer to position (B) and lock it in place by pushing the lever (2) upwards. The OS-120PT may now be stored in the case.


4.4 Conversion Curves for Schmidt OS-120PT

The typical measuring range, respectively the compressive strength range of the concrete under test lies between 1 N/mm² (145 psi) and 5 N/mm² (725 psi). Typical curves are presented for this range on the following two pages.

For the creation of own conversion curves please refer to the "SilverSchmidt Original Schmidt_Function_to_estimate_Compressive_Strength_of_Concrete_v1.04_E.xls" in the download area of the Proceq website and on the DVD provided with the instrument.


OS-120 PT Conversion Curve Cube 150/150/150

Horizontal impact direction $N/mm^2 \ y = 1.05 * (0.0009x^2 + 0.0808x - 0.5081)$
 Vertical impact direction $N/mm^2 \ y = 1.05 * (0.0015x^2 + 0.0615x - 0.3585)$



OS-120 PT Conversion Curve Cylinder 150/300


Horizontal impact direction $N/mm^2 \ y = 0.8337 * (0.0009x^2 + 0.0808x - 0.5081)$
 Vertical impact direction $N/mm^2 \ y = 0.8337 * (0.0015x^2 + 0.0615x - 0.3585)$



OS-120 PT

Conversion Curve Cube 150/150/150


Horizontal impact direction $\text{psi } y = 152.2899 * (0.0009x^2 + 0.0808x - 0.5081)$
Vertical impact direction $\text{psi } y = 152.2899 * (0.0015x^2 + 0.0615x - 0.3585)$



OS-120 PT

Conversion Curve Cylinder 150/300

Horizontal impact direction $\text{psi } y = 120.918 * (0.0009x^2 + 0.0808x - 0.5081)$
Vertical impact direction $\text{psi } y = 120.918 * (0.0015x^2 + 0.0615x - 0.3585)$



A form factor must be used to correct the conversion estimate in cases where the compressive strength is not to be used as either as standard cube compressive strength (150/150/150 cube) or a standard cylinder compressive strength (150/300 cylinder). (See the corresponding information in the document delivered with the instrument, or on the Proceq website.)

5. Measuring and Evaluation with the Schmidt OS-120PM

The OS-120PM is used to test the mortar of joints in masonry constructions non-destructively. The mortar can then be classified based on the rebound value. The classification is only valid for measurements on vertical walls.

For a detailed description of the procedures of the following three chapters 5.1, 5.2 and 5.3 refer to the chapters 4.1, 4.2 and 4.3.



NOTE! At all times ensure that all your body parts are kept away from the space between the hammer head (7) and the contact surface A.

5.1 Functional Check


The functional check of the Schmidt OS-120PM is carried out in the same way as for the Schmidt OS-102PT (see chapter 4.1).

5.2 Preparations

- Identify a suitable location on the mortar joint. If necessary, remove any dirt or moss, etc.
- The hammer (3) must be fixed at position 75 on the scale (5) and the control knob (6) turned to position V (for testing on vertical surfaces). See respective picture in chapter 4.2.

5.3 Measuring

- Grip the Schmidt OS-120PM by the handle on the housing (1). Exert a light pressure against the test surface towards the side where the contact surfaces (A) of the housing (1) are located. This ensures that the contact surfaces (A) lie flush against the surface. Additionally make certain that the joint to be tested is precisely in the middle of the circular opening of the housing (1) in position A. This will ensure that the hammer head (7) impacts on the surface of the joint. (See the picture below.)
- Using the reset lever (2), bring the hammer (3) to position B.



- Trigger the impact by pressing the trigger button (4).
- Read the rebound value from the scale (5).

Repeat the procedure as many times as the standard you are working to requires. For example, EN 12504-2 requires a minimum of 9 rebound values for calculating the median.


The rebound value determined in this way can be used to give a classification by means of the evaluation table. (See chapter 5.4).

When the measurement is completed:

- Check the Schmidt OS-120PM on the anvil (see chapter 4.1)
- Put the Schmidt OS-120PM into the neutral position. i.e. set the OS-120PM on a horizontal surface (e.g. leave it on the anvil after the control check), set the control knob (6) to position V, depress the reset lever (2) to bring the hammer (3) to position (B) and lock it in place by pushing the lever (2) upwards. The Schmidt OS-120PM may now be stored in the case.

5.4 Rating Table for Schmidt OS-120PM

The mortar joints can be classified using the rating table below.



The customer is free to create his own mortar specific rating table.

6. Technical data

	Schmidt OS-120PT	Schmidt OS-120PM
Measuring range	See chapter 4.4	See chapter 5.4
Impact energy	0.833 Nm (0.614 ft lbf)	
Accuracy (of rebound value on anvil)	typically 176 ± 3	typically 186 ± 3
Hammer mass	720 g (1.59 lb)	665 g (1.47 lb)
Hammer head diameter	40 mm (1.57")	8.0 mm (0.315")
Weight	3.45 kg (7.60 lb)	
Dimensions of housing	230 x 60 x 200 mm (9.06" x 2.36" x 7.87")	

Schmidt OS-120PT Schmidt OS-120PM

Operating temperature	-10 bis 50°C (14 bis 122°F)
Storage temperature	-10 bis 70°C (14 bis 158°F)

7. Standards and Guidelines

7.1 Standards

The rebound number is determined on the basis of the following standards: EN12504-2 (Europe), ASTM C 805 (North America), JGJ/T 23-2011 (China). Applies to Schmidt OS-120PT only.

For the creation of user defined conversion curves, we recommend the procedures described in EN 13791 (Europe), ASTM C805, ACI 228.1R (North America), JGJ T23-2011 (China), see chapter 4.4. Applies to Schmidt OS-120PT only.

7.2 Guidelines

Austrian Guideline for tunnel lining, published December 2012. Austrian Construction Association. (To determine the time for formwork removal during tunnel construction). Applies to Schmidt OS-120PT.

TNO Report BI -88-009/61.8.2060-VOE from IBBC Delft Netherlands (Mortar joint testing). Applies to Schmidt OS-120PM.

8. Part Numbers and Accessories

8.1 Units

PART NUMBER DESCRIPTION

310 06 001 OS-120PT Concrete test hammer including, operating instructions, certificate of conformity, CD with documentation, grinding stone and carrying case



310 06 002 OS-120PM Mortar test hammer including operating instructions, certificate of conformity, CD with documentation and carrying case



8.2 Accessories

PART NUMBER	DESCRIPTION
310 99 037	Grinding stone (only required for OS-120-PT)
310 06 058	Carrying case
310 10 000	Test anvil

9. Maintenance and Support

9.1 Maintenance

Maintenance includes a regular check of the instrument and cleaning of the breaking strip as described in chapter 4.1.

To guarantee consistent, reliable and accurate measurements, the instrument should be calibrated on a yearly basis. The customer may however, determine the service interval based on his own experience and usage.

Normal use may result in smaller damages to the paint, for example, inside of the housing (1) at the loading position (B) caused by the hammer (3). This will neither impair the functioning nor the life span of the Schmidt OS-120.

9.2 Support Concept

Proceq is committed to providing a complete support service for this instrument by means of our global service and support facilities. It is recommended that the user register the product on www.proceq.com to obtain the latest on available updates and other valuable information.

9.3 Standard Warranty and Extended Warranty

The standard warranty covers the mechanical portion of the instrument for 6 months.

Notes

Dotted lines for notes

Proceq Europe

Ringstrasse 2
CH-8603 Schwerzenbach
Switzerland
Phone +41 43 355 38 00
Fax +41 43 355 38 12
info-europe@proceq.com

Proceq UK Ltd.

Bedford i-lab, Priory Business Park
Stannard Way
Bedford MK44 3RZ
United Kingdom
Phone +44 123 483 45 15
info-uk@proceq.com

Proceq USA, Inc.

117 Corporation Drive
Aliquippa, PA 15001
U.S.A.
Phone +1 724 512 03 30
Fax +1 724 512 03 31
info-usa@proceq.com

Proceq Asia Pte Ltd

12 New Industrial Road
#02-02A Morningstar Centre
Singapore 536202
Phone +65 638 239 66
Fax +65 638 233 07
info-asia@proceq.com

Proceq Rus LLC

Ul. Optikov 4
korp. 2, lit. A, Office 410
197374 St. Petersburg
Russia
Phone/Fax +7 812 448 35 00
info-russia@proceq.com

Proceq Middle East

P. O. Box 8365, SAIF Zone,
Sharjah, United Arab Emirates
Phone +971 6 557 8505
Fax +971 6 557 8606
info-middleeast@proceq.com

Proceq SAO Ltd.

Rua Paes Leme, 136, cj 610
Pinheiros, São Paulo
Brasil Cep. 05424-010
Phone +55 11 3083 38 89
info-southamerica@proceq.com

Proceq China

Unit B, 19th Floor
Five Continent International Mansion, No. 807
Zhao Jia Bang Road
Shanghai 200032
China
Phone +86 21 631 774 79
Fax +86 21 631 750 15
info-china@proceq.com

Subject to change. Copyright © 2017 by Proceq SA, Schwerzenbach. All rights reserved.
Part Number: 82031002E ver 10 2017